

Niagara County Department of Health
Environmental Health Division
5467 Upper Mountain Road, Suite 100
Lockport, NY 14094-1894
(716) 439-7444
inspections@niagaracounty.com

Swimming Pool Inspection Summary Report

Operation: NEWFANE ELEMENTARY SCHOOL POOL (ID: 446676)
Facility Name: NEWFANE ELEMENTARY SCHOOL POOL
Facility Code: 31-1783 Facility Email: gnoon@newfane.wnyric.org
Facility Address: 2909 Transit Road, Newfane, NY 14108

To the Attention of:

George Noon
6273 Charlotteville Road
Newfane, NY 14108
Email: GNOON@NEWFANECENTRALSCHOOLS.ORG

Complaint Investigation

Date: February 15, 2023 10:00 AM
Inspector: Jaclyn Bald (jaclyn.bald@niagaracounty.com)
Responsible Person: Travis Dixon

Summary

Number of Public Health Hazards Found:	0
Number of Public Health Hazards NOT Corrected:	0
Number of Other Violations Found:	0

Reinspection is not Required

Each item found in violation is reported below along with the code requirement.

NO PUBLIC HEALTH HAZARDS REPORTED

NO NON-PUBLIC HEALTH HAZARDS REPORTED

Additional Information Collected During Inspection

Supervision Level at Time of Inspection: Ila
Temporary Residence / Campground: No

Water Chemistry

Disinfectant: Chlorine

Free Cl/Br (mg/L)	<u>2.0</u>	Combined Cl (mg/L)	<u>0</u>
pH	<u>7.4</u>	Total Alkalinity (mg/L)	<u>90</u>
		Flow Meter Reading (gpm)	<u>425</u>

Comments: NOTE: Complaint received re: bather illness. Pool sample taken today

NOTE: All chemical readings are within acceptable range.

NOTE: Per maintenance, chlorine controller was down for the past few months and waiting on a part. The part arrived last week and controller is now functioning properly. Maintenance staff had to use manual controls in order to maintain chlorine levels until fixed.

NOTE: Per Code, continuous operation of filtration and disinfection equipment is required at all times.



Inspector: Jaclyn Bald (jaclyn.bald@niagaracounty.com)



Received by: Travis Dixon